

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.co.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

	Asset Da	ata Information
Stock Number	XP11186	Set Serial Numbe
Set Manufacturer	ENER.G	Year Of Manufac
Set Model	E35	Price
Alter	nator Data	Date Into Stock
kVA - Prime	85	
kW - Prime	68	Open / Skid
kVA - Standby		Sound Attenuate
kW - Standby		Containerised
Volts	415	Sound Level 75%
Hz	50	Length mm
Amps @ Standby rating		Width mm
Make	Stamford	Height mm (excl
Model	UCi224G1	Height mm (incl
Serial No:	0264296/001	Colour
RCD	No	Condition
MCB ACB	3-Pole Contactor	Lighting AC / DO
PMG AREP	No	Bunded Floor
Heater	No	
Eng	gine Data	Weight - Kg
Make	MAN	Centre Point
Model	EO834E302	Corner Lifting Po
Serial No:	0452248/5362242	Forklift Pockets
Hours	14751	Trailer
Exhaust Type	In Cabinet Heat Exchange	
Bellows	Yes	Make
Voltage	24	Digital / Analog
Batteries / Battery Type	2 x AGM	Hour Meter
Battery Isolator	No	Oil
Water Jacket Heater	No	Water
Lube oil top up	Yes	Battery
Racor Filter	No	Amp
3 Way Fuel Valve	No	Volts
Fire Drop Valve	No	Hz
Fuel	Tank Data	AMF - Parallel
Skid / Free Standing	N/A	Battery Charger
Single Skin / Bunded		
Capacity Litres		Sockets
Capacity Hours @ 75%		
Fuel Gauge		
Transfer Pump		71

nformation	nformation		
Set Serial Number	1468		
Year Of Manufacture	2009		
Price	£11,800.00		
Date Into Stock	04/24		
Enclosure Data			
Open / Skid	Skid		
Sound Attenuated	Yes		
Containerised	No		
Sound Level 75% @ 7m			
Length mm	3600 ±		
Width mm	1400 ±		
Height mm (excl exhaust)	2650 ±		
Height mm (incl exhaust)	2650 ±		
Colour	Grey / Green		
Condition	Good		
Lighting AC / DC	No		
Bunded Floor	Yes		
Lifting Data / Chassis			
Weight - Kg	3100 ±		
Centre Point	No		
Corner Lifting Points	No		
Forklift Pockets	No		
Trailer	No		
Control Panel Data			
Make	ENER.G		
Digital / Analog	Digital		
Hour Meter	Yes		
Oil	Yes		
Water	Yes		
Battery	Yes		
Amp	Yes		
Volts	Yes		
Hz	Yes		
AMF - Parallel	Yes		
Battery Charger	Yes		
Additional Data			
Sockets	1 x 13 A / 240 V		
Warranty			

Ex Government Office Standby Set In good working order when removed

