

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

	Asset Data
Stock Number	XP40048
Set Manufacturer	FG Wilson
Set Model	P350

mormation			
	Set Serial Number	FGWPES01KMOA00242	
	Year Of Manufacture	2001	
	Price	£24,000.00	
	Date Into Stock	Dec 2021	

Alternator Data				
kVA	350 Prime			
kW	280			
Volts	415/240			
Hz	50			
Amps	487			
Make	Leroy Somer			
Model	LL6014B			
Serial No:	119710/02			
RCD	No			
MCB ACB	MCB 3 Pole			
PMG AREP	AREP			
Heater	Yes			
Engi	ne Data			
Make	Perkins			
Model	2006 TAG2			
Serial No:	SGB060582U1594H			
Hours	60			
Exhaust	No			
Bellows	Yes			
Voltage	24V			
Batteries / Battery Type	2 x Lead Acid			
Battery Isolator	No			
Water Jacket Heater	Yes			
Lube oil top up	No			
Racor Filter	No			
3 Way Fuel Valve	No			
Fire Drop Valve	Yes but not complete			
Fuel T	ank Data			
Skid / Free Standing	Skid			
Single Skin / Bunded	Single			
Capacity Litres	500			
Capacity Hours @ 75%	8 1/2			
Fuel Gauge	Yes			
Transfer Pump	No			

-			
Enclosure Data			
Open / Skid	Skid		
Sound Attenuated	Yes		
Containerised	No		
Sound Level 75% @ 7m	n/a		
Length mm	7420		
Width mm	2730		
Height mm (excl exhaust)	2750		
Height mm (incl exhaust)	n/a		
Colour	Grey		
Condition	Good		
Lighting AC / DC	Yes AC		
Bunded Floor	Yes		
Lifting Da	ta / Chassis		
Weight Kg	7100 Dry		
Corner / Centre Point	On chassis corner		
Forklift Pockets	No		
Trailer	No		
Control Panel Data			
Make	FG Wilson 4101E		
LED / Analog	Analog		
Hour Meter	Yes		
Oil	Yes		
Water	Yes		
Battery	Yes		
Amp	Yes		
Volts	Yes		
Hz	Yes		
AMF - Parallel	AMF		
Battery Charger	Yes		
Additional Data			
Sockets	No		

Additional cabinet on side with 800A incoming MCB and 2 x 63A MCB, 2 x 250A MCB, 8 x 160A MCB.

Ex office block standby generator.

Offered with a UK warranty of 6 months or 250 hours whichever first.

