

Used Generator Information

T: 01953 454540 F: 01953 456968

E: enquiries@stuartgroup.info

W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

Asset Data Information

Stock Number	XP6002
Set Manufacturer	ENER-G
Set Model	

Set Serial Number	1403
Year Of Manufacture	2008
Price	£32,000.00
Date Into Stock	April 2021

Alternator Data

kVA	610 Prime
kW	488
Volts	415/240
Hz	50
Amps	880
Make	Stamford
Model	HC-I544E1
Serial No:	0246613/001
RCD	No
MCB ACB	850 amp / 3-Pole
PMG AREP	Yes
Heater	No

Engine Data

Make	Perkins
Model	4008-30TRS1 Gas
Serial No:	DEHH01D5U164275
Hours	65,000
Exhaust Type	Yes
Bellows	Yes
Voltage	24
Batteries / Battery Type	2 x AGM
Battery Isolator	Yes
Water Jacket Heater	Yes
Lube oil top up	Yes
Racor Filter	No
3 Way Fuel Valve	No

Fuel Tank Data

Skid / Free Standing	N/A
Single Skin / Bunded	
Capacity Litres	
Capacity Hours @ 75%	
Fuel Gauge	
Transfer Pump	

Enclosure Data

Open / Skid	Skid
Sound Attenuated	Yes
Containerised	No
Sound Level 75% @ 7m	70 dba Est.
Length mm	4640
Width mm	2860
Height mm (excl exhaust)	2756
Height mm (incl exhaust)	N/A
Colour	Grey
Condition	Good
Lighting AC / DC	Yes
Bunded Floor	Yes

Lifting Data / Chassis

Weight Kg	11,000
Corner / Centre Point	No
Forklift Pockets	No
Trailer	No

Control Panel Data

Make	ENER-G
LED / Analog	Yes
Hour Meter	
Oil	
Water	
Battery	
Amp	
Volts	
Hz	
AMF - Parallel	Yes
Battery Charger	Yes

Additional Data

Sockets	1 x 13 Amp
---------	------------

Gas CHP Generator.

In running order (these engines are good for 100,000 plus hours before major overhaul). Ex NHS hospital In silent canopy to about 65 dba at 1 mts. Has sustained some minor damage during removal.



Authorised Dealer