

Used Generator Information

T: 01953 454540 F: 01953 456968

E: enquiries@stuartgroup.info

W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

Asset Data Information

Stock Number	XP11008
Set Manufacturer	Dale Power
Set Model	MNE1000

Set Serial Number	182911P1
Year Of Manufacture	2019
Price	£99,500.00
Date Into Stock	December 2021

Alternator Data

kVA	1135 Standby
kW	908
Volts	400/230
Hz	50
Amps	1638
Make	Stamford
Model	HCI 634K1
Serial No:	X18G284707
RCD	No
MCB ACB	MCB 4-Pole 1600A
PMG AREP	PMG
Heater	Yes

Engine Data

Make	MTU
Model	16V2000G62F 3B
Serial No:	545101363
Hours	8
Exhaust Type	Yes - Roof mounted
Bellows	Yes
Voltage	24V
Batteries / Battery Type	Yes - 4 x Sealed Lead
Battery Isolator	Yes
Water Jacket Heater	Yes
Lube oil top up	Yes and Rotary Pump
Racor Filter	Yes, Triplex
3 Way Fuel Valve	No
Fire Drop Valve	Yes

Fuel Tank Data

Skid / Free Standing	Free standing
Single Skin / Bunded	Single skin
Capacity Litres	1600
Capacity Hours @ 75%	11 Hours
Fuel Gauge	Yes
Transfer Pump	No

Enclosure Data

Open / Skid	Skid
Sound Attenuated	Yes
Containerised	Yes
Sound Level 75% @ 7m	70dba
Length mm	9380
Width mm	3010
Height mm (excl exhaust)	3300
Height mm (incl exhaust)	4300
Colour	White
Condition	Like New
Lighting AC / DC	AC
Bunded Floor	Yes

Lifting Data / Chassis

Weight Kg	18989 wet
Corner / Centre Point	Corner
Forklift Pockets	No
Trailer	No

Control Panel Data

Make	Deepsea DSE 7310 MK2
LED / Analog	LED
Hour Meter	Yes
Oil	Yes
Water	Yes
Battery	Yes
Amp	Yes
Volts	Yes
Hz	Yes
AMF - Parallel	AMF
Battery Charger	Yes

Additional Data

Sockets	No
---------	----

Set from cancelled project. Only test hours.
Gravity louveres on Outlet. Motorised louveres on Inlet.
UK Warranty - 12 months or 3,000 hours, 24 months or 1,000 hours from date of commissioning.
* Must have service agreement with Stuart Group or agreed by Stuart Group.*



Authorised Dealer

All Diesel Generators Are Inspected And Tested Prior To Dispatch