

Used Generator Information

Asset Data Information	
Stock Number	P11003
Set Manufacturer	Cummins
Set Model	C1100D5
Set Serial Number	
Year Of Manufacture	Jun-12
Price	£46,000.00
Date Into Stock	Oct-15
Alternator Data	
kVA	1210 Standby
kW	968
Volts	400/230
Hz	50
Amps	1742
Make	Stamford
Model	HCI 634 K1
Serial No:	A12C 119303
RCD	No
MCB ACB	ACB
PMG AREP	
Heater	
Engine Data	
Make	Cummins
Model	QST30-G4
Serial No:	37253734
Hours	10,000
Exhaust	Roof
Bellows	Yes
Voltage	24
Batteries / Battery Type	4 x Lead Acid
Battery Isolator	Yes
Water Jacket Heater	Yes
Lube oil top up	Yes
Racor Filter	Yes
3 Way Fuel Valve	TBA
Fuel Tank Data	
Skid / Free Standing	No
Single Skin / Bunded	
Capacity Litres	
Capacity Hours @ 75%	
Fuel Gauge	
Transfer Pump	
Enclosure Data	
Open / Skid	No
Sound Attenuated	Yes
Containerised	Yes
Sound Level 75% @ 1m	80 dBA
Length mm	10,000
Width mm	2,400
Height mm (excl exhaust)	2,500
Height mm (incl exhaust)	2,800
Colour	White
Condition	Good
Lighting AC / DC	Yes
Bunded Floor	Yes
Lifting Data / Chassis	
Weight Kg	19,500
Corner / Centre Point	Yes / No
Forklift Pockets	Yes
Trailer	ISO
Control Panel Data	
Make	Deep Sea
LED / Analog	LED
Hour Meter	Yes
Oil	Yes
Water	Yes
Battery	Yes
Amp	Yes
Volts	Yes
Hz	Yes
AMF - Parallel	AMF
Battery Charger	Yes
Additional Data	
Sockets	

This set was used as prime power to a grinding mill. Has been run for 40 hours per week within a large building. It has been serviced @ 250 hour intervals by a Cummins dealer. A bulk tank is available at extra cost.



All Diesel Generators Are Inspected And Tested Prior To Dispatch