

Used Generator Information

Asset Data Information

Stock Number	XP80023
Set Manufacturer	Aries Power Plant
Set Model	720 R35

Set Serial Number	99/4220
Year Of Manufacture	1999
Price	£26,000.00
Date Into Stock	03/21

Alternator Data

kVA	800kVA Standby
kW	640kW
Volts	415/240
Hz	50
Amps	1113
Make	Stamford Newage
Model	HC.I634J1
Serial No:	0111122/01
RCD	No
MCB ACB	MCB
PMG AREP	PMG
Heater	No

Engine Data

Make	Perkins
Model	3012 TAG2A
Serial No:	SGC120000U1531F
Hours	Less than 500
Exhaust	No
Bellows	Yes
Voltage	24
Batteries / Battery Type	2 x Lead Acid
Battery Isolator	Yes
Water Jacket Heater	Yes
Lube oil top up	No
Racor Filter	No
3 Way Fuel Valve	No

Fuel Tank Data

Skid / Free Standing	Skid
Single Skin / Bunded	Bunded
Capacity Litres	1559
Capacity Hours @ 75%	13
Fuel Gauge	Yes
Transfer Pump	Yes

Enclosure Data

Open / Skid	Yes
Sound Attenuated	No
Containerised	No
Sound Level 75% @ 1m	-
Length mm	3840
Width mm	1970
Height mm (excl exhaust)	2830
Height mm (incl exhaust)	N/A
Colour	Grey
Condition	Good
Lighting AC / DC	No
Bunded Floor	Yes

Lifting Data / Chassis

Weight Kg	8500
Corner / Centre Point	No
Forklift Pockets	No
Trailer	No


Control Panel Data

Make	Deepsea 4520
LED / Analog	LED
Hour Meter	Yes
Oil	Yes
Water	Yes
Battery	Yes
Amp	Yes
Volts	Yes
Hz	Yes
AMF - Parallel	AMF
Battery Charger	No

Additional Data

Sockets	No
---------	----

Ex office Standby Unit



Authorised Dealer

All Diesel Generators Are Inspected And Tested Prior To Dispatch