

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

Asset I	
Stock Number	XP79
Set Manufacturer	Stuart Group Ltd
Set Model	7.5S

a Information		
	Set Serial Number	18E1366/1
	Year Of Manufacture	2017
	Price	4,150.00
	Date Into Stock	May 2022

Alternator Data		
kVA	7.5	
kW	6	
Volts	230	
Hz	50	
Amps	33	
Make	Stamford	
Model	P1044F1	
Serial No:	B17B072611	
RCD	No	
MCB ACB	MCB	
PMG AREP	No	
Heater	No	
Engi	ne Data	
Make	Perkins	
Model	403D-11	
Serial No:	GJ65605U 183806C	
Hours	1 - Test only	
Exhaust Type	Loose single	
Bellows	Flanged Flexy pipe.	
Voltage	12V	
Batteries / Battery Type	1 x Lead Acid	
Battery Isolator	No	
Water Jacket Heater	No	
Lube oil top up	No	
Racor Filter	No	
3 Way Fuel Valve	No	
Fire Drop Valve	No	
Fuel Tank Data		
Skid / Free Standing	Skid	
Single Skin / Bunded	Single	
Capacity Litres	66	
Capacity Hours @ 75%	31 Hours	
Fuel Gauge	Yes	
Transfer Pump	No	

Enclosure Data			
Open / Skid	Yes		
Sound Attenuated	No		
Containerised	No		
Sound Level 75% @ 1m	No		
Length mm	1260		
Width mm	715		
Height mm (excl exhaust)	1040		
Height mm (incl exhaust)	n/a		
Colour	Black		
Condition	Good		
Lighting AC / DC	No		
Bunded Floor	No		
Lifting Data / Chassis			
Weight Kg	460kg		
Corner / Centre Point	No		
Forklift Pockets	No		
Trailer	No		
Control F	Panel Data		
Make	Deep Sea DSE7110		
LED / Analog	LED		
Hour Meter	Yes		
Oil	Yes		
Water	Yes		
Battery	Yes		
Amp	Yes		
Volts	Yes		
Hz	Yes		
AMF - Parallel	AMF		
Battery Charger	No		
Additional Data			
Sockets	No		
Sump Pump			

Control panel is loose with loom.

