

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

	Asset Data
Stock Number	XP80029
Set Manufacturer	Perkins
Set Model	-

IIIIOIIIIatioii			
	Set Serial Number	07E7532	
	Year Of Manufacture	2006	
	Price	POA	
	Date Into Stock	October 2022	

Alternator Data			
kVA	800 prime		
kW	640		
Volts	400/230		
Hz	50		
Amps	1156		
Make	Stamford		
Model	HCI634G1		
Serial No:	0223989/007		
RCD .	No		
MCB ACB	MCB 3 Pole		
PMG AREP	No		
Heater	No		
Engine Data			
Make	Perkins		
Model	4006-23TAG3A		
Serial No:	DGD06224804202N		
Hours	40		
Exhaust Type	Twin on roof		
Bellows	Yes		
Voltage	24V		
Batteries / Battery Type	Lead Acid		
Battery Isolator	No		
Water Jacket Heater	Yes		
Lube oil top up	No		
Racor Filter	No		
3 Way Fuel Valve	No		
Fire Drop Valve	No		
Fuel Ta	nk Data		
Skid / Free Standing	Skid		
Single Skin / Bunded	Single skin		
Capacity Litres	1550		
Capacity Hours @ 75%	12		
Fuel Gauge	Yes		
Transfer Pump	No		

Enclosure Data		
Skid		
Yes		
Close fit		
78dba		
6000		
1890		
2500		
3100		
White / Blue		
Good		
No		
No		
Lifting Data / Chassis		
8500 dry		
Corner on chassis		
No		
No		
Control Panel Data		
Deep Sea 521		
Both		
Yes		
AMF		
TBC		
Additional Data		
TBC		

Ex office block standby.

Sold with a UK warranty of 3 months or 250 hours whichever first.

