

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

	Asset Date	
Stock Number	XP70012	
Set Manufacturer	FG Wilson	
Set Model	P750SX	

a Information			
ŀ	Set Serial Number	T9021/2	
	Year Of Manufacture	1989	
	Price	£25,500.00	
	Date Into Stock	October 2022	

Alternator Data			
kVA	750 Standby		
kW	600		
Volts	415/240		
Hz	50		
Amps	1044		
Make	Stamford		
Model	HC634A		
Serial No:	Y2620/01		
RCD	No		
MCB ACB	MCB 3 Pole		
PMG AREP	PMG		
Heater	No		
Engin	e Data		
Make	Perkins		
Model	3012TAG3		
Serial No:	6A27099U6457T		
Hours	525		
Exhaust Type	Loose		
Bellows	Yes		
Voltage	24V		
Batteries / Battery Type	4 x Lead Acid		
Battery Isolator	No		
Water Jacket Heater	Yes		
Lube oil top up	No		
Racor Filter	No		
3 Way Fuel Valve	No		
Fire Drop Valve	No		
Fuel Tank Data			
Skid / Free Standing	Skid		
Single Skin / Bunded	Bunded		
Capacity Litres	1200		
Capacity Hours @ 75%	8 hours		
Fuel Gauge	Yes		
Transfer Pump	Yes		

Enclosure Data				
Open / Skid	Yes			
Sound Attenuated	No			
Containerised	No			
Sound Level 75% @ 7m				
Length mm	TBC			
Width mm	TBC			
Height mm (excl exhaust)	TBC			
Height mm (incl exhaust)	TBC			
Colour	Blue			
Condition	Used			
Lighting AC / DC	No			
Bunded Floor	No			
Lifting Data / Chassis				
Weight Kg	TBC			
Corner / Centre Point	Corner on chassis			
Forklift Pockets	No			
Trailer	No			
Control Panel Data				
Make	FG Wilson 4000 Series			
LED / Analog	Both			
Hour Meter	Yes			
Oil	Yes			
Water	Yes			
Battery	Yes			
Amp	Yes			
Volts	Yes			
Hz	Yes			
AMF - Parallel	AMF			
Battery Charger	Yes			
Additional Data				
Sockets	No			

