


LT-Motor rating and performance curve

Curve/Impeller No	Rated Power, kW	Rated current, A	Starting current, A	Power factor cos φ	Ex proof version available
400 V, 50 Hz, 3 ~, 2945 r/min					
231	20	36	315	0,90	
232	20	36	315	0,90	


Y/D starting current is approximately 1/3 of D starting current.



MT-Motor rating and performance curve

Curve/Impeller No	Rated Power, kW	Rated current, A	Starting current, A	Power factor cos φ	Ex proof version available
400 V, 50 Hz, 3 ~, 2945 r/min					
241	20	36	315	0,90	

Y/D starting current is approximately 1/3 of D starting current.



HT-Motor rating and performance curve

Curve/Impeller No	Rated Power, kW	Rated current, A	Starting current, A	Power factor $\cos \varphi$	Ex proof version available
400 V, 50 Hz, 3 ~, 2945 r/min					
233	20	36	315	0,90	
234	20	36	315	0,90	

Y/D starting current is approximately 1/3 of D starting current.

